
APPLICATION NO: F/YR22/0869/F

SITE LOCATION: 7 Station Road, Manea

UPDATE

Consultee Comments

Cambridgeshire Fire and Rescue

With regard to the above application, should the Planning Authority be minded to grant approval, the Fire Authority would ask that adequate provision be made for fire hydrants, which may be by way of Section 106 agreement or a planning condition.

The position of fire hydrants are generally agreed upon when the Water Authority submits plans to:

*Water & Planning Manager
Community Fire Safety Group
Hinchingbrooke Cottage
Brampton Road
Huntingdon
Cambs
PE29 2NA*

Where a Section 106 agreement or a planning condition has been secured, the cost of Fire Hydrants will be recovered from the developer.

The number and location of Fire Hydrants will be determined following Risk Assessment and with reference to guidance contained within the "National Guidance Document on the Provision of Water for Fire Fighting" 3rd Edition, published January 2007.

Access and facilities for the Fire Service should also be provided in accordance with the Building Regulations Approved Document B5 Vehicle Access. Dwellings Section 13 and/or Vol 2. Buildings other than dwellings Section 15 Vehicle Access.

If there are any buildings on the development that are over 11 metres in height (excluding blocks of flats) not fitted with fire mains, then aerial (high reach) appliance access is required, the details of which can be found in the attached document.

I trust you feel this is reasonable and apply our request to any consent given.

Resolution: No change to the recommendation which is to refuse the application as per Section 12 of Agenda item 7 on page 87