

PLANNING COMMITTEE DATE: 29 July 2020

Agenda No: 6

APPLICATION NO: F/YR19/0761/F

SITE LOCATION: Lattersey Field, Benwick Road, Whittlesey

UPDATE

Condition 3 to be updated with the relevant plan number as follows:

Prior to the first use of any building hereby permitted external lighting shall be provided as per drawings 19006-E-EX-2002 C5, 19006-ME-EX-3001 C3, 19006-E-EX-2001 C4 and the External Light Pollution Assessment.

The perimeter lights shall be switched off and remaining lighting dimmed between the hours of 2200 -0700 (as indicated on drawing 19006-E-EX-2002 C5).

Reason - To ensure that adequate lighting of the development is provided during the hours of darkness for security purposes, and to ensure the development does not cause harm to ecology or the amenity of adjoining occupiers in accordance with Policies LP2, LP16, LP17 and LP19 of the Fenland Local Plan 2014.

Resolution: No change to the recommendation which is to grant the application as per Section 12 of Agenda item 6.